



EXECUTIVE SUMMARY

davenport community school district

Acres Owned: 527 total
Population: 14,114 students
Grades Served: Pre-K - 12th grade
Average Classroom Size: 837 sq. ft.

District Average
Building Age

70
years old


District ADA
Condition Overview




District Site
Condition Overview



● 17 Elementary ● 1 K-8 School ● 4 Junior High ● 4 High School



Historical District Enrollment 2012-2022




sudlow junior high ada condition + assessment

Overall Condition Rating:




Most Concerning Item
That Does Not Meet Code
Requirements:



*Not providing at least 18" minimum
clearance required on the pull side
of the door, parallel to doorway.*

Most Frequently Occurring
Item That Does Not Meet
Code Requirements:



*Not providing at proper grab bars at
ADA accessible toilet*

GENERAL ASSESSMENT OF ADA CONDITIONS

■ Building Entrance Accessibility

■ ADA Parking Stalls

■ Accessible Routes of Travel

- Ramps
- Lifts
- Elevators

■ Railings

- Ramp Railings
- Stair Railings

■ Door Hardware

■ Door Clearances

- Push / Pull
- Thresholds
- Maneuvering

■ Toilet Rooms

- 5'-0" Wheelchair Clearance
- ADA Accessible Stall
- Unisex Toilet Room
- Grab Bars
- Showers

■ Protruding Objects

■ Drinking Fountains

■ Casework

- Transaction Counters
- Workstations Counters
- Counters with Sinks

west high school site assessment

